No. C0110-B

Fire Suppression

CERTIFICATE

13 NOV 2015 /16/2202

This is to certify that Amsco Fire Ltd. Has carried out a yearly maintenance Service on a fire suppression system to the required Standard at :

Park View Suites (Bunker), Rear of Charing House, Canterbury St, Gillingham

Details:

Design standard:	BS9251:2005
Design risk:	4 Head - 30 minute min. R.T.
Head Type:	74 Degree, Concealed sprinkler
Head info:	Viking 457, 49 lpm, min 0.5 bar
No. Heads	45
Max coverage:	15 sq. mtrs.
Min 1 Head activation:	60 lpm

Deviations:

1/. Concealed sprinkler heads.

2/. Partial Cover (Ground/First Flrs

Pump & Tank

Tank : Cylindrical Plastic 6000litre.

Pump: Grifen 003131.

232LPM @ 4.8Bar.

Audio visual alarm

System interfaced with main fire alarm with an external strobe sounder fitted to plant room.

Installed by : **Amsco Fire Ltd**
Innovation Centre
Highfield Drive
Churchfields
St.Leonards on Sea
East Sussex
TN38 9UH

Tel: 01424 813131

www.amscofire.co.uk

Client : Charing Health Ltd

Designed by : K. Haines

Date commissioned : 24/01/2014

Engineer : David Vicarey

Signed :

Managing Director